



Electrical Services Division
14849 -124 Avenue
Edmonton, AB T5L 3B2
Phone: (780) 434-8421
Fax: (780) 437-2658
1-866-285-5550 Branch Ext 26

Unit will consist of the following

- A welded and powder coated free standing steel frame, on wheels.
- A 30 amp 600V safety switch
- 3 meters feet of 4c10 SOOW cable with a 60 amp APJ cord end (welding plug).
- A 10 KVA BEMAG dual voltage transformer, 1 phase, 600/480 – 120/240.
- A 1 phase, 100 amp, 120/240V Square D load center, 8 circuits.
- A 8 outlet receptacle enclosure.
- 8 – 15 amp 125 volt “T” slotted GFCI receptacle on a 15 amp QO Square D breaker.



TCRS model: Mini Power Center

All temporary power units will be completely wired, tested and CSA approved; NEMA 3R outdoor use.